

TYPE EXAMINATION CERTIFICATE

No. 13-514 of 10/07/13

Name of organization: **UGent, Department of Textiles** issues this certificate.

1. Product name: PVC floor tile
2. Product material: PVC
3. Product type:
 - a) thickness: 1.1 mm – 5.0 mm
 - b) density: $1970 \pm 50 \text{ kg/m}^3$
4. Numerical code of product classification:
 - a) fire behaviour: **B_f s1**
 - b) formaldehyde: **E1**
 - c) slip resistance: **DS**
5. Usage of the product: flooring
6. Manufacturer: Zhangjiagang Yihua Plastic Co., Ltd.
7. Address: Yangshe Town Industry Development Area, Zhangjiagang, Jiangsu , China


This certificate assures the compliance of properties of the product, which complies with the technical requirements referenced in EN 14041 – EN 9239 -1 and EN 717-1. The certificate only applies to materials that correspond to the tested sample.


The results of tests and findings on conformity of the properties of the given type with technical requirements given in EN 14041 – EN 9239 -1, EN 717-1 and EN 13893 are referenced in classification report CR-13-514/01, Test Reports 13-514A, 13-514B, 13-514C and FCHL-307/13.

Date of issuing: 10/07/13

Valid until: 2018

Department of Textiles of Ghent University is recognized as notified laboratory 1611 for the European regulation 305/2011 for construction products.


Didier Van Daele
Head of floorcovering/fire tests


Stijn Rimbout
Head of chemical tests

 Prof. Dr. Paul KIEKENS, dr. h. c.
Head of Department